

To: Ham, Greg[Ham.Greg@epa.gov]; Richardson, Todd[Richardson.Todd@epa.gov]; DiDonato, Ann[DiDonato.Ann@epa.gov]; Lapsley, Glen[Lapsley.Glen@epa.gov]
Cc: Gross, Bonnie[Gross.bonnie@epa.gov]; Heston, Gerald[Heston.Gerald@epa.gov]; Burns, Francis[Burns.Fran@epa.gov]; Boyd, Kevin[Boyd.Kevin@epa.gov]; Steuteville, William[Steuteville.William@epa.gov]; Santiago, Cindy[Santiago.Cindy@epa.gov]; Miller, Lori[Miller.Lori@epa.gov]; R3 RRC[R3_RRC@epa.gov]
From: Zenone, Vincent
Sent: Fri 8/26/2016 2:43:53 AM
Subject: NRC Report #: 1157352
[NRC Report #1157352.pdf](#)

FYI... SPOKE WITH PEMA EARLIER THIS EVENING WHEN FOLLOWING-UP ANOTHER NRC REPORT, PEMA INFORMED ME THEY WERE BUSY WORKING AN INCIDENT – A RELEASE OF NATURAL GAS AT A REGULATOR STATION IN NEW OXFORD, ADAMS CO., PA. THE INCIDENT WAS CAUSED WHEN A VEHICLE RAN INTO THE FACILITY. SEE SYNOSIS OF PEMA UPDATES IN ACTION REPORT BELOW.

MOST RECENT PEMA UPDATE AT 2220 HOURS: COLUMBIA GAS IS EXPECTED TO ENTER THE BUILDING IN LEVEL IV HAZMAT SUITS WITHIN 2 HOURS. MET-ED HAS TURNED OFF ELECTRIC ON RT. 94 NORTH TO RT. 394. YORK COUNTY MOBILE COMMAND UNIT IS ON SCENE ASSISTING.

Action Report

DataID: [967145](#)

Date: 2016/08/25	Time: 22:12	Submitted by: R03 Duty Officer
Duty Officer/Responder Name: ZENONE	NRC Report #: 1157352	Hotline Log DataID: 2014042
Action Information		
<p>Description:1805 hrs - A ten-inch gas line has been struck by a truck at a substation and is leaking at 3316 Carlisle Pike (SR 94) in Hamilton Township, Adams County. Columbia Gas has been notified but has provided no ETA. The County advises that evacuations are possible. There are no unmet needs and the County will update as they can. - EJR</p> <p>1822 hrs - Command requesting evacuation for an area 1/2 mile north of the incident scene. This involves a currently unknown number of homes/people. The New Oxford Fire Company is serving as the evacuation center. Local EMA is on the scene and County is still attempting to contact County EMA. There is still no ETA for Columbia Gas. - EJR</p> <p>1854 hrs - An evacuation of a 1/2 mile radius of the station is currently in progress. Unknown how many residents affected. SR 94 is closed in the area. Adams County requested the CWWC send an EAS message on their behalf. No unmet needs at this time.</p> <p>2115 hrs - Columbia Gas is on scene working to turn off the 10" gas main. There are two valves in the building that need to be turned off. Met-Ed is on scene and is in the process of turning off the power. 15 people arrived at the shelter located at the United Hook and Ladder Fire Dept in New Oxford. Other</p>		

residents in the area have went to friends or relatives. The Cross Keys Village has been asked to shelter in place. The county is monitoring the weather - nothing adverse at this time. Wind direction continues to the north. The county has no unmet needs at this time. The CWWC is at an enhanced level. – RCT